



# Technical Memorandum

<b>To:</b>	Andrea Lacy Bourbon County Joint Planning Commission	<b>Date:</b>	July 31, 2019
<b>From:</b>	GRW Engineers	<b>GRW Project No.:</b>	4602-04
<b>Subject:</b>	<b>CMWA Construction Plans and Stormwater Calculations – Revised Per Original Comments</b>		

## I. Comments

Below are comments on the revised CMWA Construction Plans and Drainage Report submitted by Palmer Engineering. New plans and calculations were submitted based on comments in a previous memo dated 7/23/19.

### Construction Plans:

- **Sheet C-1.0**
  - Revise pavement sections to match geotechnical report.

## II. Recommendations

Our comments were satisfactorily addressed with the revised plan and calculation submittal. A revised utility plan was not submitted, but the City should ensure its utilities are satisfied with the plan per comments brought forth at the TRC meeting held on 7/24/19.