

From: Robert Baldwin <becrlb@att.net>

Sent: Tuesday, March 14, 2023 11:52 AM

To: dbsoper1989@gmail.com <dbsoper1989@gmail.com>; Mike Johnson
<mike@magtraceinfo.com>

Subject: Re: Box curb vs. Roll curb

Mike,

The design of all of our storm water collections systems presumes that rolled curb will be used. We do not use box curb unless the final authority that is responsible maintaining the street system requires box curb. We do not recommend that box curb be used in areas that are to be developed because of the number of times that the curb needs to be cut for driveways. Further, the rolled curb has the same water handling capacity as box curb.

Thanks,

Bob

Robert L. Baldwin, PE, PLS
Baldwin Engineering Corporation
P. O. Box 4315
Winchester, KY 40392-4315
859-744-6943
becrlb@att.net

